




**CERTIFICATE FOR SAFE DRINKING WATER AND SANITARY CONDITION**

MIP/MCN/MDP/PR/16/2024-25

Dated: 14-06-2024

It is certified that an inspection team headed by DR. RAKESH.N MEDICAL OFFICER OF HEALTH & SREENIVASAPPAN SR.HI(Name of Officers with designation) from BBMP HEALTH DEPARTMENT PHED inspected the VAGDEVI VILAS SCHOOL SY.NO121/5, Chikkaturupathi Road, Varthur, Bangalore-560087 (Name & Address of the school) on 14-06-2024 (date of inspection) and on the basis of Water Test Report (Attached) bearing no ULR NO: TC-1255424000000910F dated: 27-03-2024 of IADFAC LABORATORIES PVT LTD (PHED Lab) certified that the VAGDEVI VILAS SCHOOL ( Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.  
This certificate is valid till :14-06-2025

Signature with Seal:   
Name : DR. RAKESH.N  
Designation : MEDICAL OFFICER OF HEALTH  
Name & Address of the Office: ಬೆಂಗಳೂರು ಪೞ್ಯಾಭಿಷಾಂಗಣ : BBMP ಸಹದೇವಪುರ ವಲಯ ಬೆಂಗಳೂರು

To  
VAGDEVI VILAS SCHOOL  
SY.NO121/5, Chikkaturupathi Road,  
Varthur, Bangalore-560087 (Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

For VAGDEVI VILAS SCHOOL  
  
Chairman

  
Principal  
Vagdevi Vilas School  
Varthur, Bengaluru-560 087



**PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION**

**"SEAL TRANSLATION" CERTIFICATE**

MEDICAL OFFICER OF HEALTH  
MAHADEVAPURA ZONE, BBMP.  
BBMP/MOH/MDP/PR/16/2024-25

Dated:14-06-2024

It is certified that an inspection team headed by DR. RAKESH.N MEDICAL OFFICER OF HEALTH & SREENIVASAPPA.N SR.HI(Name of Officers with designation) from BBMP HEALTH DEPARTMENT PHED inspected the VAGDEVI VILAS SCHOOL SY.NO121/5, Chikkatirupathi Road, Varthur, Bangalore-560087 (Name & Address of the school) on 14-06-2024 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no ULR NO: TC-1255424000000910F dated: 27-03-2024 of IADFAC LABORATORIES PVT LTD (PHED Lab)

certified that the VAGDEVI VILAS SCHOOL ( Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.  
This certificate is valid till :14-06-2025

Signature with Seal:

Name : DR. RAKESH.N  
Designation : MEDICAL OFFICER OF HEALTH  
Name & Address of the Office: BBMP

**ಮಹದೇವಪುರ ವಲಯ  
ಆರೋಗ್ಯ**

**"SEAL TRANSLATION"  
MEDICAL OFFICER OF HEALTH  
MAHADEVAPURA ZONE  
BENGALURU**

To  
VAGDEVI VILAS SCHOOL  
SY.NO121/5, Chikkatirupathi Road,  
Varthur, Bangalore-560087 (Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



ATTESTED BY ME

K.V. JAGANNATH REDDY, B.A., LL.B.  
ADVOCATE & NOTARY PUBLIC  
GOVT. OF INDIA  
No. 326, 2nd Cross, Behind Tulasa Theatre  
Marathahalli, Bangalore - 560075

For VAGDEVI VILAS SCHOOL

25 JUN 2024

**Principal**  
Vagdevi Vilas School  
Varthur, Bengaluru-560 087

**Chairman**



INSTITUTE FOR ANALYSIS OF DAIRY, FOOD & CULTURES.  
 #3, Siddhi Vinayaka Complex, Nagarabhavi 2nd Stage, 2nd Block  
 Near BDA Complex, 80 Feet Ring Road, Bangalore-560 072  
 Ph: +91-80-2318 6906/07, Cell: +91 8152880444/8152881222  
 Mail: accounts@iadfacs.com/bd@iadfacs.org/qa@iadfacs.com



**TEST REPORT**

BOOKING NO. : 0881  
 REPORT NO. : 0881/2024-2025

ULR No. : TC-125542400000910F

**NAME OF MANUFACTURER/PARTY :** VAGDEVI VILAS SCHOOL.....  
 Chikkalrupathi Road, Varthur  
 BANGALORE - 560087 KARNATAKA

1. MFG. LIC. NO. : NM  
 2. REFERENCE NO. : NM  
 3. DATE : 25/04/2024  
 4. DATE OF RECEIPT : 25/04/2024  
 5. NAME OF SAMPLE : R O Water

**6. DETAILS OF RAW MATERIAL / FINAL PRODUCTS (In Bulk/Finished Pack)**

(A) MANUFACTURER NAME : NM	(B) BATCH NO. : NM
(C) BATCH SIZE : NM	(D) DATE OF MFG. : NM
(E) SAMPLE QUANTITY : 5Lx1 & 2500ml	(F) DATE OF EXPIRY : NM
(G) PACKING : Sterile bottle & Plastic Can	(H) STARTING DATE : 25/04/2024
(I) SEALED : Sealed	(J) ENDING DATE : 03/05/2024
(K) BRAND NAME : NM	(L) SAMPLING PROTOCOL : NA
(M) DATE OF SAMPLING /SAMPLE COLLECTION : 25/04/2024	(N) REPORT GEN. DATE : 04/05/2024

**Specification as per IS 10500:2012**

SR	TEST NAME	UNIT	RESULT	ACCEPTABLE LIMIT	PERMISSIBLE LIMIT	METHOD OF TEST
I	BIOLOGICAL TESTING					
	Water					
1	Coliform	/100ml	Absent	Shall not be detectable in 100ml sample	No relaxation	IS 15185
2	E coli	/100ml	Absent	Shall not be detectable in 100ml sample	No relaxation	IS 15185
II	CHEMICAL TESTING					
	Water					
1	Colour	HU	<1	5 Max	15 Max	IS 3025 (part 4)
2	Odour	-	Agreeable	Agreeable	Agreeable	IS 3025 (Part 5)
3	pH Value	-	6.5	6.5-8.5	No Relaxation	IS 3025 (PART 11)
4	Taste	-	Agreeable	Agreeable	Agreeable	IS 3025 (Part 7 & 8) :2017
5	Turbidity	NTU	<1	1 Max	5 Max	IS 3025 (Part 10)
6	Total Dissolved Solids	mg/l	42.0	500 Max	2000 Max	IS 3025 ( PART 16)
7	Aluminium ( as Al )	mg/l	<0.02	0.03 Max	0.2 Max	IS 3025 (PART 55)
8	Anionic detergents (as MBAS )	mg/l	<0.1	0.2 Max	1.0 Max	IS 13428
9	Barium ( as Ba )	mg/l	<0.5	0.7 Max	No Relaxation	IS 13428
10	Borates ( as Boron )	mg/l	<0.1	0.5 Max	2.4 Max	IS 3025 (Part 57)
11	Calcium ( as Ca )	mg/l	1.0	75 Max	200 Max	IS 3025 (Part 40)
12	Chloride (as Cl )	mg/l	9.0	250 Max	1000 Max	IS 3025 (Part 32)
13	Fluoride ( as F )	mg/l	0.17	1.0 Max	1.5 Max	IS 3025 (Part 60)

Remarks : The Sample complies to the specifications as per the above tested parameters.  
 For IADFAC Laboratories Pvt. Ltd.

For IADFAC Laboratories Pvt. Ltd

For VAGDEVI VILAS SCHOOL  
 Authorised Signatory: Dr. Rashmi B Artal (ID No. 167)  
 CONTD. ON NEXT PAGE  
 Chairman: Ullas Kumbhar (ID No. 125)  
 AUTHORIZED SIGNATORY

**Note :**  
 1. The results listed refer only to the samples analysed & applicable parameters. Endorsement products is neither inferred nor implied.  
 2. Total liability of our institute is limited to the invoiced amount.  
 3. The report cannot be reproduced, completely or in part, in any form of media (including print) without our explicit written permission from IADFAC Lab.  
 4. Sample drawn and submitted by the party for Analysis unless otherwise stated.  
 5. Analysed Food samples are destroyed After one month.

Principal  
 Vagdevi Vilas School  
 Varthur, Bengaluru-560 087



INSTITUTE FOR ANALYSIS OF DAIRY, FOOD & CULTURES.  
 #8, Siddhi Vinayaka Complex, Nagarabhalvi 2nd Stage, 2nd Block  
 Near BDA Complex, 80 Feet Ring Road, Bangalore-560 072  
 Ph: +91-80-2318 6906/07, Cell : +91 8152880444/8152881222  
 Mail: accounts@iadfacs.com/bd@iadfacs.org/ga@iadfacs.com



**TEST REPORT**

BOOKING NO. : 0881

REPORT NO. : 0881/2024-2025

ULR No. : TC-125542400000910F

**NAME OF MANUFACTURER/PARTY :** VAGDEVI VILAS SCHOOL.....  
 Chikkaturupathi Road, Varthur  
 BANGALORE - 560087 KARNATAKA

1. MFG. LIC. NO. : NM  
 2. REFERENCE NO. : NM  
 3. DATE : 25/04/2024  
 4. DATE OF RECEIPT : 25/04/2024  
 5. NAME OF SAMPLE : R.O Water

**6. DETAILS OF RAW MATERIAL / FINAL PRODUCTS (In Bulk/Finished Pack)**

(A) MANUFACTURER NAME : NM (B) BATCH NO. : NM  
 (C) BATCH SIZE : NM (D) DATE OF MFG. : NM  
 (E) SAMPLE QUANTITY : 5Lx1 & 2500ml (F) DATE OF EXPIRY : NM  
 (G) PACKING : Sterile bottle & Plastic Can (H) STARTING DATE : 25/04/2024  
 (I) SEALED : Sealed (J) ENDING DATE : 03/05/2024  
 (K) BRAND NAME : NM (L) SAMPLING PROTOCOL : NA  
 (M) DATE OF SAMPLING /SAMPLE COLLECTION : 25/04/2024 (N) REPORT GEN. DATE : 04/05/2024

**Specification as per IS 10500:2012**

SR	TEST NAME	UNIT	RESULT	ACCEPTABLE LIMIT	PERMISSIBLE LIMIT	METHOD OF TEST
14	Free residual Chlorine	mg/l	<0.1	0.2 Min	1.0 Max	IS 3025 (PART 26)
15	Magnesium ( as Mg )	mg/l	<1.0	30 Max	100 Max	IADFAC/VIC09, 2022 Issue no-01, Issue date 07.02.2022
16	Nitrate (as NO3)	mg/l	4.46	45 Max	No Relaxation	IS 3025 ( Part 34 )
17	Phenolic Compounds ( as C6H5OH )	mg/l	<0.001	0.001 Max	0.002 Max	IS 3025 (Part 43)
18	Sulphate ( as SO4 )	mg/l	<1.0	200 Max	400 Max	IS 3025 (PART 24)
19	Sulphide ( as H2S )	mg/l	<0.05	0.05 Max	No Relaxation	IS 3025 (Part 29)
20	Total Alkalinity as calcium carbonate	mg/l	6.0	200 Max	600 Max	IS 3025 (PART 23)
21	Total Hardness ( as CaCO3 )	mg/l	2.0	200 Max	600 Max	IS 3025 (PART 21)
22	Cyanide ( as CN )	mg/l	<0.01	0.05 Max	No Relaxation	IS 3025 : Part 27
23	Polychlorinated Biphenyle ( PCB )					
a	2,6-Di chloro biphenyl	mg/l	<0.00005	0.0005 Max	No Relaxation	APHA 8431C 24th edition
b	2,4,4 Trichloro biphenyl	mg/l	<0.00005	0.0005 Max	No Relaxation	APHA 8431C 24th edition
c	2,2,5,5-Tetrachloro biphenyl	mg/l	<0.00005	0.0005 Max	No Relaxation	APHA 8431C 24th edition
d	2,2,4,4,5,5 Hexachloro biphenyl	mg/l	<0.00005	0.0005 Max	No Relaxation	APHA 8431C 24th edition
e	2,2,3,4,4,5,-Hexa chloro biphenyl	mg/l	<0.00005	0.0005 Max	No Relaxation	APHA 8431C 24th edition
f	2,2,3,4,4,5,5 Heptachloro biphenyl	mg/l	<0.00005	0.0005 Max	No Relaxation	APHA 8431C 24th edition
24	Poly Nuclear Aromatic Hydrocarbons ( PAH )					

Remarks : The Sample complies to the specifications as per the above tested parameters.

For VAGDEVI VILAS SCHOOL

For IADFAC Laboratories Pvt. Ltd.

CONTD. ON NEXT PAGE.....

Chairman

Authorised Signatory  
 Ullas Kumbhar (ID No. 125)

**Note :**

- The results listed, refer only to the samples analysed & applicable parameters, Endorsement products is neither inferred nor implied.
- Total liability of our institute is limited to the invoiced amount.
- The report cannot be reproduced, completely or in part, in any form of media (including print) without an explicit written permission from IADFAC Lab.
- Sample drawn and submitted by the party for Analysis unless otherwise stated.
- Analysed Food samples are destroyed After one month.

**Principal**  
 Vagdevi Vilas School  
 Varthur, Bengaluru-560 087

## TEST REPORT

BOOKING NO. : 0881

REPORT NO. : 0881/2024-2025

ULR No. : TC-125542400000910F

NAME OF MANUFACTURER/PARTY : VAGDEVI VILAS SCHOOL.....  
 Chikkatirupathi Road, Varthur

BANGALORE - 560087 KARNATAKA

1. MFG. LIC. NO. : NM  
 2. REFERENCE NO. : NM  
 3. DATE : 25/04/2024  
 4. DATE OF RECEIPT : 25/04/2024  
 5. NAME OF SAMPLE : RO Water

6. DETAILS OF RAW MATERIAL / FINAL PRODUCTS (In Bulk/Finished Pack)

(A) MANUFACTURER NAME : NM (B) BATCH NO. : NM  
 (C) BATCH SIZE : NM (D) DATE OF MFG. : NM  
 (E) SAMPLE QUANTITY : 5Lx1 & 2500ml (F) DATE OF EXPIRY : NM  
 (G) PACKING : Sterile bottle & Plastic Can (H) STARTING DATE : 25/04/2024  
 (I) SEALED : Sealed (J) ENDING DATE : 03/05/2024  
 (K) BRAND NAME : NM (L) SAMPLING PROTOCOL : NA  
 (M) DATE OF SAMPLING/SAMPLE COLLECTION : 25/04/2024 (N) REPORT GEN. DATE : 04/05/2024

Specification as per IS 10500:2012

SR	TEST NAME	UNIT	RESULT	ACCEPTABLE LIMIT	PERMISSIBLE LIMIT	METHOD OF TEST
a	Anthracene	mg/l	<0.00005	0.0001 Max	No Relaxation	APHA 6440C 24th Edition
b	Phenanthrene	mg/l	<0.00005	0.0001 Max	No Relaxation	APHA 6440C 24th edition
c	Benzo (a)anthracene	mg/l	<0.00005	0.0001 Max	No Relaxation	APHA 6440C 24th edition
d	Benzo (b) fluoranthene	mg/l	<0.00005	0.0001 Max	No Relaxation	APHA 6440C 24th edition
e	Benzo (g,h,i) pyrene	mg/l	<0.00005	0.0001 Max	No Relaxation	APHA 6440C 24th edition
f	Benzo (g,h,i) Perylene	mg/l	<0.00005	0.0001 Max	No Relaxation	APHA 6440C 24th edition
g	Fluoranthene	mg/l	<0.00005	0.0001 Max	No Relaxation	APHA 6440C 24th edition
h	Indeno (1,2,3-c,d) pyrene	mg/l	<0.00005	0.0001 Max	No Relaxation	APHA 6440C 24th edition
i	Acenaphthene	mg/l	<0.00005	0.0001 Max	No Relaxation	APHA 6440C 24th edition
j	Acenaphthylene	mg/l	<0.00005	0.0001 Max	No Relaxation	APHA 6440C 24th edition
k	Fluorene	mg/l	<0.00005	0.0001 Max	No Relaxation	APHA 6440C 24th edition
l	Pyrene	mg/l	<0.00005	0.0001 Max	No Relaxation	APHA 6440C 24th edition
m	Dibenzo(a,h) anthracene	mg/l	<0.00005	0.0001 Max	No Relaxation	APHA 6440C 24th edition
25	Mineral Oil	mg/l	<0.5	0.5 Max	No Relaxation	IS 3025 Part 39
26	Copper (as Cu)	mg/l	<0.05	0.05 Max	1.5 Max	IADFAC/VC09, 2022 Issue no-01, Issue date 07.02.2022
27	Iron ( as Fe )	mg/l	<0.05	0.3 Max	No Relaxation	IS 3025 : Part 53
28	Manganese ( as Mn )	mg/l	<0.05	0.1 Max	0.3 Max	IADFAC/VC09, 2022 Issue no-01, Issue date 07.02.2022

For VAGDEVI VILAS SCHOOL

For IADFAC Laboratories Pvt. Ltd.

Remarks : The Sample complies to the specifications as per the above tested parameters

*K. Gowtham*  
 Chairman

*Ullas Kumbhar*  
 AUTHORIZED SIGNATORY  
 Ullas Kumbhar (ID No. 125)

CONTD. ON NEXT PAGE.....

Note :

- The results listed, refer only to the samples analysed & applicable parameters, Endorsement products is neither inferred nor implied.
- Total liability of our institute is limited to the invoiced amount.
- The report cannot be reproduced, completely or in part, in any form of media (including print) without our written permission from IADFAC Lab.
- Sample drawn and submitted by the party for Analysis unless otherwise stated.
- Analysed Food samples are destroyed After one month.

Principal  
 Vagdevi Vilas School  
 Varthur, Bengaluru-560 087

## TEST REPORT

BOOKING NO. : 0881

ULR No. : TC-125542400000910F

REPORT NO. : 0881/2024-2025

NAME OF MANUFACTURER/PARTY : **VAGDEVI VILAS SCHOOL.....**  
 Chikkatinupathi Road, Varthur

BANGALORE - 560087 KARNATAKA

1. MFG. LIC. NO. : NM  
 2. REFERENCE NO. : NM  
 3. DATE : 25/04/2024  
 4. DATE OF RECEIPT : 25/04/2024  
 5. NAME OF SAMPLE : RO Water

**6. DETAILS OF RAW MATERIAL / FINAL PRODUCTS (In Bulk/Finished Pack)**

(A) MANUFACTURER NAME : NM  
 (B) BATCH NO. : NM  
 (C) BATCH SIZE : NM  
 (D) DATE OF MFG. : NM  
 (E) SAMPLE QUANTITY : 5Lx1 & 2500ml  
 (F) DATE OF EXPIRY : NM  
 (G) PACKING : Sterile bottle & Plastic Can  
 (H) STARTING DATE : 25/04/2024  
 (I) SEALED : Sealed  
 (J) ENDING DATE : 03/05/2024  
 (K) BRAND NAME : NM  
 (L) SAMPLING PROTOCOL : NA  
 (M) DATE OF SAMPLING / SAMPLE : 25/04/2024  
 (N) REPORT GEN. DATE : 04/05/2024

**Specification as per IS 10500:2012**

SR	TEST NAME	UNIT	RESULT	ACCEPTABLE LIMIT	PERMISSIBLE LIMIT	METHOD OF TEST
29	Selenium ( as Se )	mg/l	<0.005	0.01 Max	No Relaxation	IADFAC/V/C09, 2022 Issue no-01, Issue date 07.02.2022
30	Silver ( as Ag )	mg/l	<0.01	0.1 Max	No Relaxation	IADFAC/V/C09, 2022 Issue no-01, Issue date 07.02.2022
31	Zinc ( as Zn )	mg/l	0.05	5.0 Max	15 Max	IADFAC/V/C09, 2022 Issue no-01, Issue date 07.02.2022
32	Cadmium ( as Cd )	mg/l	<0.003	0.003 Max	No Relaxation	IADFAC/V/C09, 2022 Issue no-01, Issue date 07.02.2022
33	Lead ( as Pb )	mg/l	<0.01	0.01 Max	No Relaxation	IADFAC/V/C09, 2022 Issue no-01, Issue date 07.02.2022
34	Mercury ( as Hg )	mg/l	<0.0005	0.001 Max	No Relaxation	IADFAC/V/C09, 2022 Issue no-01, Issue date 07.02.2022
35	Nickel ( as Ni )	mg/l	<0.01	0.02 Max	No Relaxation	IADFAC/V/C09, 2022 Issue no-01, Issue date 07.02.2022
36	Total Arsenic ( as As )	mg/l	<0.005	0.01 Max	No Relaxation	IADFAC/V/C09, 2022 Issue no-01, Issue date 07.02.2022
37	Total Chromium ( as Cr )	mg/l	<0.05	0.05 Max	No Relaxation	IADFAC/V/C09, 2022 Issue no-01, Issue date 07.02.2022
1	Pesticide residues Alochlor	ug/l	<0.01	20 Max	No Relaxation	APHA 6630D 24th edition

For IADFAC Laboratories Pvt. Ltd.

Remarks : The Sample complies to the specifications as per the IS 10500:2012 standards for **VAGDEVI VILAS SCHOOL**

*K. Ramesh*  
 Chairman

*[Signature]*  
 Authorised Signatory

CONTD. ON NEXT PAGE

Ullas Kumar (ID No. 125)

**Note :**

- The results listed, refer only to the samples analysed & applicable parameters, Endorsement products is neither inferred nor implied.
- Total liability of our institute is limited to the invoiced amount.
- The report cannot be reproduced, completely or in part, in any form of media (including print) without an explicit written permission from IADFAC Lab.
- Sample drawn and submitted by the party for Analysis unless otherwise stated.
- Analysed Food samples are destroyed After one month.

**Principal**  
**Vagdevi Vilas School,**  
 Varthur, Bangalore-560087

## TEST REPORT

BOOKING NO. : 0881

ULR No. : TC-125542400000910F

REPORT NO. : 0881/2024-2025

NAME OF MANUFACTURER/PARTY : VAGDEVI VILAS SCHOOL.....  
 Chikkatrurpathi Road, Varthur

BANGALORE - 560087 KARNATAKA

1. MFG. LIC. NO. : NM  
 2. REFERENCE NO. : NM  
 3. DATE : 25/04/2024  
 4. DATE OF RECEIPT : 25/04/2024  
 5. NAME OF SAMPLE : R O Water  
 6. DETAILS OF RAW MATERIAL / FINAL PRODUCTS (In Bulk/Finished Pack)  
 (A) MANUFACTURER NAME : NM  
 (B) BATCH NO. : NM  
 (C) BATCH SIZE : NM  
 (D) DATE OF MFG. : NM  
 (E) SAMPLE QUANTITY : 5Lx1 & 2500ml  
 (F) DATE OF EXPIRY : NM  
 (G) PACKING : Sterile bottle & Plastic Can  
 (H) STARTING DATE : 25/04/2024  
 (I) SEALED : Sealed  
 (J) ENDING DATE : 03/05/2024  
 (K) BRAND NAME : NM  
 (L) SAMPLING PROTOCOL : NA  
 (M) DATE OF SAMPLING /SAMPLE COLLECTION : 25/04/2024  
 (N) REPORT GEN. DATE : 04/05/2024

### Specification as per IS 10500:2012

SR	TEST NAME	UNIT	RESULT	ACCEPTABLE LIMIT	PERMISSIBLE LIMIT	METHOD OF TEST
2	Alomn/Dielomn	µg/l	<0.01	0.03 Max	No Relaxation	APHA 6630D 24th edition:
3	Alpha HCH	µg/l	<0.01	0.01 Max	No Relaxation	APHA 6630D 24th edition:
4	Beta HCH	µg/l	<0.01	0.04 Max	No Relaxation	APHA 6330 D 24th edition:
5	Gamma-HCH	µg/l	<0.01	2 Max	No Relaxation	APHA 6330 D 24th edition:
6	Burachlor	µg/l	<0.01	125 Max	No Relaxation	EPA 8141 B
7	Chlorpyrifos	µg/l	<0.01	30 Max	No Relaxation	EPA 8141 B
8	Delta HCH	µg/l	<0.01	0.04 Max	No Relaxation	APHA 6630D 24th edition:
9	2,4-Dichlorophenoxyacetic acid	µg/l	<0.025	30 Max	No Relaxation	IADFACV/C06, 2018: Issue No:01, Issue Date:06.09.2018
10	DDT					
a	o,p-DDE	µg/l	<0.01	1 Max	No Relaxation	APHA6630D 24th edition:
b	o,p-DDD	µg/l	<0.01	1 Max	No Relaxation	APHA6630D 24th edition:
c	o,p-DDT	µg/l	<0.01	1 Max	No Relaxation	APHA6630D 24th edition:
d	p,p-DDE	µg/l	<0.01	1 Max	No Relaxation	APHA6630D 24th edition:
e	p,p-DDD	µg/l	<0.01	1 Max	No Relaxation	APHA6630D 24th edition:
f	p,p-DDT	µg/l	<0.01	1 Max	No Relaxation	APHA6630D 24th edition:
11	Endosulfan					
a	Alpha Endosulfan	µg/l	<0.01	0.4 Max	No Relaxation	APHA6630D 24th edition:
b	Beta Endosulfan	µg/l	<0.01	0.4 Max	No Relaxation	APHA6630D 24th edition:

For IADFAC Laboratories Pvt. Ltd.

Remarks : The Sample complies to the specifications as per the above tested parameters.

For VAGDEVI VILAS SCHOOL

CONTD. ON NEXT PAGE

Authorised Signatory  
 Ullas Kulkarni (ID No. 125)

Chalunan

### Note :

- The results listed refer only to the samples analysed & applicable parameters. Endorsement products is neither inferred nor implied.
- Total liability of our institute is limited to the invoiced amount.
- The report cannot be reproduced, completely or in part, in any form of media (including print) without our explicit written permission from IADFAC Lab.
- Sample drawn and submitted by the party for Analysis unless otherwise stated.
- Analysed Food samples are destroyed After one month.

Principal  
 Vagdevi Vilas School  
 Varthur, Bengaluru-560 072

## TEST REPORT

BOOKING NO. : 0881

ULR No. : TC-125542400000910F

REPORT NO. : 0881/2024-2025

NAME OF MANUFACTURER/PARTY : VAGDEVI VILAS SCHOOL.....  
 Chikkaturupathi Road, Varthur

BANGALORE - 560087 KARNATAKA

1. MFG. LIC. NO. : NM  
 2. REFERENCE NO. : NM  
 3. DATE : 25/04/2024  
 4. DATE OF RECEIPT : 25/04/2024  
 5. NAME OF SAMPLE : R.O Water

6. DETAILS OF RAW MATERIAL / FINAL PRODUCTS (In Bulk/Finished Pack)

(A) MANUFACTURER NAME : NM  
 (B) BATCH NO. : NM  
 (C) BATCH SIZE : NM  
 (D) DATE OF MFG. : NM  
 (E) SAMPLE QUANTITY : 5Lx1 & 2500ml  
 (F) DATE OF EXPIRY : NM  
 (G) PACKING : Sterile bottle & Plastic Can  
 (H) STARTING DATE : 25/04/2024  
 (I) SEALED : Sealed  
 (J) ENDING DATE : 03/05/2024  
 (K) BRAND NAME : NM  
 (L) SAMPLING PROTOCOL : NA  
 (M) DATE OF SAMPLING /SAMPLE : 25/04/2024  
 (N) REPORT GEN. DATE : 04/05/2024

Specification as per IS 10500:2012

SR	TEST NAME	UNIT	RESULT	ACCEPTABLE LIMIT	PERMISSIBLE LIMIT	METHOD OF TEST
c	Endosulfan sulphate	µg/l	<0.01	0.4 Max	No Relaxation	APHA6630D 24th edition:
12	Ethion	µg/l	<0.01	3 Max	No Relaxation	EPA 8141B
13	Isoproturon	µg/l	<0.01	9 Max	No Relaxation	IADFAC/IC07R Issue No.02, Issue Date:26/06/2028
14	Malathion	µg/l	<0.01	190 Max	No Relaxation	EPA 8141B
15	Monocrotophos	µg/l	<0.025	1 Max	No Relaxation	EPA 8141B
16	Phorate	µg/l	<0.01	2 Max	No Relaxation	EPA 8141B
17	Methyl Parathion	µg/l	<0.01	0.3 Max	No Relaxation	EPA 8141B

For VAGDEVI VILAS SCHOOL

*K. Kulkarni*  
 Chairman

For IADFAC Laboratories Pvt. Ltd.

Remarks : The Sample complies to the specifications as per the above tested parameters.

End Of Report

Authorised Signatory  
 Uilas Kumbhar (ID No. 12554)

Note :

- The results listed refer only to the samples analysed & applicable parameters. Endorsement products is neither inferred nor implied.
- Total liability of our institute is limited to the invoiced amount.
- The report cannot be reproduced, completely or in part, in any form of media (including print) without our explicit written permission from IADFAC Lab.
- Sample drawn and submitted by the party for Analysis unless otherwise stated.
- Analysed Food samples are destroyed After one month.

Principal  
 Vagdevi Vilas School  
 Varthur, Bengaluru-560 087

## TEST REPORT

BOOKING NO. : 0881A  
 REPORT NO. : 0881A/2024-2025

**NAME OF MANUFACTURER/PARTY :** VAGDEVI VILAS SCHOOL.....  
 Chikkalirupathi Road, Varthur  
 BANGALORE - 560087 KARNATAKA

1. MFG. LIC. NO. : NM  
 2. REFERENCE NO. : NM  
 3. DATE : 25/04/2024  
 4. DATE OF RECEIPT : 25/04/2024  
 5. NAME OF SAMPLE : R O Water  
 6. DETAILS OF RAW MATERIAL / FINAL PRODUCTS (In Bulk/Finished Pack)

(A) MANUFACTURER NAME : NM  
 (B) BATCH NO. : NM  
 (C) BATCH SIZE : NM  
 (D) DATE OF MFG. : NM  
 (E) SAMPLE QUANTITY : 5L  
 (F) DATE OF EXPIRY : NM  
 (G) PACKING : Plastic can  
 (H) STARTING DATE : 29/04/2024  
 (I) SEALED : Sealed  
 (J) ENDING DATE : 03/05/2024  
 (K) BRAND NAME : NM  
 (L) SAMPLING PROTOCOL : NA  
 (M) DATE OF SAMPLING /SAMPLE COLLECTION : 25/04/2024  
 (N) REPORT GEN. DATE : 04/05/2024

### Specification as per IS 10500:2012

SR	TEST NAME	UNIT	RESULT	ACCEPTABLE LIMIT	PERMISSIBLE LIMIT	METHOD OF TEST
I	CHEMICAL TESTING					
	RESIDUES IN Water					
1	Ammonia (as total ammonia- N)	mg/l	<0.1	0.5 Max	No Relaxation	IS 3025 (Part-34) : 1988
2	Chloramines (as Cl <sub>2</sub> )	mg/l	<0.01	4.0 Max	No Relaxation	IS 3025 (Part-26) : 1988
3	Molybdenum ( as Mo )	mg/l	<0.05	0.07 Max	No Relaxation	IADFAC/V/C09
4	Pesticide residues					
a	Atrazine	µg/l	<0.01	2 Max	No Relaxation	EPA 8141B
5	Trihalomethanes					
a	Bromoform	mg/l	<0.01	0.1 Max	No Relaxation	APHA 4th Edition Chapter no 6232
b	Dibromochloro methane	mg/l	<0.01	0.1 Max	No Relaxation	APHA 4th Edition Chapter no 6232
c	Bromodichloro Methane	mg/l	<0.01	0.06 Max	No Relaxation	APHA 4th Edition Chapter no 6232
d	Chloroform	mg/l	<0.01	0.2 Max	No Relaxation	APHA 4th Edition Chapter no 6232

*[Signature]*  
**Principal**  
 Vagdevi Vilas School  
 Varthur, Bengaluru-560 087

*[Signature]*  
**For VAGDEVI VILAS SCHOOL**

*[Signature]*  
**For IADFAC Laboratories Pvt. Ltd.**

Remarks : The Sample complies to the specifications as per the above tested parameters.

*[Signature]*  
**Chairman**

*[Signature]*  
**Authorised Signatory**  
 Ullas

End Of Report

### Note :

- The results listed, refer only to the samples analysed & applicable parameters, Endorsement products is neither inferred nor implied.
- Total liability of our institute is limited to the invoiced amount.
- The report cannot be reproduced, completely or in part, in any form of media (including print) without an explicit written permission from IADFAC Lab.
- Sample drawn and submitted by the party for Analysis unless otherwise stated.
- Analysed Food samples are destroyed After one month.